

Surface Water Discharge Monitoring

EPL No:	20581
Date of Reported Results	12.5.20

Pollutant	Unit*	Frequency	Monitoring Point 1					
			17/09/19	07/02/20	04/03/20	05/03/20	16/03/20	30/04/20
pH	pH	Following discharge event	6.7	7.72	7.9	7.33	7.46	7.7
Total Suspended Solids, TSS	mg/L	Following discharge event	8	**	13	13	<5	<5
Nitrogen (ammonia)	mg/L	Following discharge event	0.01	0.02	0.83	0.06	0.12	0.09
Biochemical Oxygen Demand	mg/L	Following discharge event	8	<2	4	<2	<2	<2
Oil & Grease	mg/L	Following discharge event	<5	<5	<5	<5	<5	<5

* Unit of Measure Abbreviations	
Milligrams per Litre	mg/L

*Sample taken from Humeceptor outlet

**Testing of Total Suspended Solids was missed for this round