

Monitoring Data From 01-Dec-2020 To 31-Dec-2020

VEOLIA WATER AUSTRALIA PTY LTD 268 CROOKED RIVER ROAD GERROA NSW 2534

Environmental Protection Licence 11317

Gerringong Gerroa Sewage Treatment Scheme EFFLUENT MONITORING POINT 23

	BOD	Total Nitrogen	Total Phosphorous	Suspended Solids	Faecal Coliforms	рН	Oil and Grease	Comments
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(/100mL)		(mg/L)	
Number of Samples	5	5	5	5	5	5	0	
Minimum Value	1	1.01	0.021	1	1	7.1		
Maximum Value	1	1.85	0.032	1	4	7.2		
Monitoring frequency required by licence	Every 6 days	Every 6 days	Every 6 days	Every 6 days	Every 6 days	Every 6 days	Quarterly	
100 Percentile Limits						6.5 - 9	10	
Limit of Detection (LOD)*	2	0.05	0.002	2	1	0.1	5	

^{*} Where the laboratory result is below LOD, values are input as half the LOD to allow for statistical analysis, excluding faecal coliform bacteria which is input as zero where < 1

Note: An additional table which summarises the yearly 50th percentile limits will be included to allow comparison with the performance limit.

Date Published: 10-Nov-2020 Page 1 of