

Sydney Water Corporation

From 01/Aug/2022 To 31/Aug/2022

Monthly EPL Report Gerringong Gerroa Sewerage Scheme

EPL Licence 11317

Effluent Monitoring Point 23

								1
		Total	Total	Suspended	Faecal			`
	BOD	Nitrogen	Phosphorus	Soilds	Coliforms	рН	Oil & Grease	
Units	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(/100mL)	рН	(mg/L)	
Compliance limit	<5	<3	<0.1	<3	<2			
Number of Samples	5	5	5	5	5	5	0	
Minimum	1	1.10	0.011	1	0	6.90		
Maximum	1	1.47	0.017	1	0	7.30		
Monitoring frequency								
required by licence	Every 6 days	Quarterly						
100 Percentile Limits						6.5 - 9	10	
Limits of Detection (LoD)*	2	0.05	0.002	2	1	0.1	5	/

NOTES

BOD - Biochemical Oxygen Demand

 * Where the laboratory result is below LoD, values are input as half the LoD to allow for statistical analysis, excluding faecal coliform bacteria which is input as zero where <1

Sydney Water Corportation - Monthly EPL Report

Page 1 of 1