



May 2025

VEOLIA WATER OPERATIONS PTY LTD

PO Box 2891

Taren Point BC NSW 2229

Iaren Point BC NSW 222												
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Annual Limits		Min.	10%-ile	Median	Average	90%-ile	Max.	Comments / explanation
EPL 12904				10%-ile Limit	90%-ile Limit							
Monitoring Point 8												
Conductivity	microsiemens per centimetre	Continuous during discharge	Continuous during discharge	-	-	8	44,922	65,762	59,253	72,873	76,208	
Temperature	celsius	Continuous during discharge	Continuous during discharge	-	-	14.96	19.50	20.53	20.60	21.95	24.04	
Salinity	-	Continuous during discharge	Continuous during discharge	-	72	0.01	32.41	48.31	44.02	54.69	59.39	
Oxidation Reduction Potential	millivolts	Continuous during discharge	Continuous during discharge	-	-	208.69	276.64	316.86	313.83	342.40	508.98	
pH	pH	Continuous during discharge	Continuous during discharge	6.5	8.8	5.01	7.46	7.61	7.60	7.76	8.02	
Total dissolved solids	milligrams per litre	Weekly during any discharge	4	-	-	28,900	30,520	40,450	40,325	50,030	51,500	
Total residual chlorine	milligrams per litre	Daily during any discharge	31	-	0.1	0.04	0.04	0.04	0.04	0.04	0.04	
Total suspended solids	milligrams per litre	Weekly during any discharge	4	-	30	2.00	2.00	2.00	2.00	2.00	2.00	
Turbidity	nephelometric turbidity units	Daily during any discharge	31	-	-	0.20	0.20	0.20	0.21	0.30	0.30	

Note 1: The table above is analysing the monthly data against annual limits. A table that analyses the annual data against the annual limits prescribed above will be published in January of each year.
<https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?id=12904&option=licence&range=PEO%20licence&searchrange=>

Published: 2025Jun03